60-Second Smoke Detector Compliance Checklist

💡 ***Disclaimer:*** *This checklist offers a quick reference only. Fire safety codes vary by jurisdiction and building type. For full compliance, consult a certified fire safety professional or local authority.*

☐ **Spacing & placement:**

- ☐ No detector more than 30 feet from another
- ☐ All units within 12 inches of ceiling
- ☐ 10+ feet from HVAC vents

☐ **Critical areas:**

- ☐ Above suspended ceilings
- ☐ Every elevator shaft
- ☐ All stairwell levels
- ☐ Mechanical rooms
- ☐ Electrical rooms

☐ **Current maintenance:**

- ☐ Monthly tests logged
- ☐ Batteries dated
- ☐ Annual inspection valid
- ☐ No expired components
- ☐ Clean, unobstructed units

☐ **Red flags:**

- ☐ Missing documentation
- ☐ Trouble lights active
- ☐ Visible damage
- ☐ Outdated models (10+ years)

FORBEL
CUSTOM SECURITY SOLUTIONS